

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400

Group Number Assessment

(In accordance with AS 5637.1-2015)

This is to confirm that the product as described below has been tested by AWTA Product Testing .

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

Test Number : 20-004271

Issue Date : 4/09/2020

Print Date : 4/09/2020

Sponsor Product

Clients Ref : Birch Plywood

Veneer Plywood

End Use : Walls-Ceilings-Partitions

Nominal Composition : Birch Veneers

Nominal Mass per Unit Area/Density : 680-760kg/m3

Nominal Thickness : 12mm

Product Group Number Classification :

3

Average Specific Extinction Area :

45.8 m²/kg



Chris Campbell
Client Relations Manager